



LCIE



**TEST REPORT
IEC/EN 62109-1**

**Safety of Power Converter for use in Photovoltaic Power Systems
Part 1: General requirements**

Report

Report Reference No.....: ZEK-ESH-P21011135-1-R1

Date of issue.....: 2021-10-09

Total number of pages: 73

Tested by (function+name+signature): Tony Huang
Test Engineer

Approved by (function+name+signature): Denis sun
Project Manager

Testing Laboratory: LCIE China Company Limited

Address.....: Building 4, No. 518, Xinzhuang Road, Caohejing Songjiang High-Tech Park, Shanghai, P.R.China (201612)

Applicant's name: ALTENERGY POWER SYSTEM INC.

Address.....: No.1 Yatai Road, Jiaxing 314050 Zhejiang Province, P.R. China

Test specification:

Standard: IEC 62109-1:2010

EN 62109-1:2010

Test procedure.....: CE-LVD

Non-standard test method.....: N/A

This report is for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence, provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents

Test item description: Grid-tied Microinverter

Trade Mark



Manufacturer.....: **ALTENERGY POWER SYSTEM INC.**

Model/Type reference.....: DS3, DS3-H, DS3-L, DS3-L-SPE, DS3-S

Ratings.....: See next page

7.3.7	TABLE: clearance and creepage distance measurements					P
clearance cl and creepage distance dcr at / of:	Up (V)	U r.m.s. (V)	required cl (mm)	cl (mm)	required dcr (mm)	dcr (mm)
Model: DS3-H						
L line to PE(BI)	--	230	3,0	5,5	3,0	5,5
PV to PE(BI)	60	--	1,5	6,5	1,5	6,5
Main circuit to SELV circuit(FI)	--	230	3,0	5,5	3,0	5,5
SPS transformer T5 Primary to Secondly(RI)	--	230	5,5	5,6	5,5	5,6
X capacitor to earth(PE) under PCB(BI)	--	230	3,0	5,5	3,0	5,5
Notes: BI: Basic insulation; RI: Reinforced insulation DI: Double insulation						